

**EMERGENCY** COMMUNICATION INSTRUCTIONS

2.7 P. L. T. 1.7 F

PUSH BUTTON FOR HELP

F1.7 -1.6657 B 656F

AUDIBLE TONE AND LED INDICATE CALL HAS BEEN PLACED.

AFTER OPERATORS' INSTRUCTIONS, WAIT FOR TONE TO BEGIN SPEAKING.

FLOOR 2 SOUTH ELEVATOR

FLT FLEEDE B HAFF



### **Features**

- Dimensions: 12.5" x 14.5"
- .040" aluminum sign with white epoxy finish
- · 1/32" raised text and braille designed specifically for Chapter 7 Section 703.3 of ICC A117.1
- Required per IBC 1009.11 3 and NFPA72 2016 24.10.8
- · High strength foam adhesive for easy installation
- · Custom location text with braille available

# **Emergency** Communication Instructions with **Custom Location**

### **EMERGENCY** COMMUNICATION **INSTRUCTIONS**

>59#4.03 LDL970.9 2.7 P.1.7 17 1

#### PUSH BUTTON FOR HELP

F17 114457 H 551F

AUDIBLE TONE AND LED INDICATE CALL HAS BEEN PLACED.

AFTER OPERATORS' INSTRUCTIONS, WAIT FOR TONE TO BEGIN SPEAKING. FLOOR 2 SOUTH ELEVATOR

PLT TIPPER H POLE

Instructions and compliance are a critical part of the Shield30 Emergency Communication System. This instruction sign with an option for a custom location specifically follows the guidelines in Chapter 7 Section 703 of ICC A117.1.

## **Specifications**

The 12.5" x 14.5" aluminum Emergency Communications Instructions shall be finished with a white epoxy with blue graphics for high visibility and endurance. Blue 1/32" raised text and braille will be designed specifically to comply with Chapter 7 Section 703.3 of ICC A117.1. Sign shall be mounted above or adjacent to each emergency call station per IBC Section 1009.11. Location, including braille shall be included on each sign. Mounting the sign: visual characters shall be 40 inches (1015 mm) minimum and a maximum of 60 inches (1524 mm) above the finish floor or ground.

# **Ordering Information**

P/N# **Description** 

SGSIGN1 12.5" x 14.5" Emergency Communication

Instructions



